

Recommendation: Delete entire section but for the following: Insulation shields provided as part of a listed chimney system shall be installed in accordance with the manufacturer's installation instructions.

Reason: Should be installed by manufactured installations instructions.